



February 13, 2024

Michael Ferraro  
OHM BOCES Utica City School District  
320 Elizabeth St.  
Utica, NY 13501

RE: Project: JEFFERSON ELEMENTARY 2/6  
Pace Project No.: 70286737

Dear Michael Ferraro:

Enclosed are the analytical results for sample(s) received by the laboratory on February 08, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jack M. Germano  
jack.germano@pacelabs.com  
516-370-6012  
Project Manager

Enclosures

cc: Erica Molina, OHM BOCES Utica City School District  
OHM BOCES Safety Services, OHM BOCES Utica City  
School District  
Tiffany Service, OHM BOCES Utica City School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 01		Lab ID: 70286737001	Collected: 02/06/24 06:32	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 10:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 02		Lab ID: 70286737002	Collected: 02/06/24 06:34	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 10:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 03		Lab ID: 70286737003	Collected: 02/06/24 06:34	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>22.5</b>	ug/L	1.0	1		02/13/24 11:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 04		Lab ID: 70286737004	Collected: 02/06/24 06:36	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		02/13/24 11:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 05	Lab ID: 70286737005	Collected: 02/06/24 06:39	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>12.0</b>	ug/L	1.0	1		02/13/24 11:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 06		Lab ID: 70286737006	Collected: 02/06/24 06:41	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		02/13/24 11:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 07		Lab ID: 70286737007	Collected: 02/06/24 06:41	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.4</b>	ug/L	1.0	1		02/13/24 11:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 08		Lab ID: 70286737008	Collected: 02/06/24 06:44	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.6</b>	ug/L	1.0	1		02/13/24 11:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 09		Lab ID: 70286737009	Collected: 02/06/24 06:44	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>13.3</b>	ug/L	1.0	1		02/13/24 11:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 10		Lab ID: 70286737010	Collected: 02/06/24 06:46	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		02/13/24 11:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 11		Lab ID: 70286737011	Collected: 02/06/24 06:46	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		02/13/24 11:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 12		Lab ID: 70286737012	Collected: 02/06/24 06:48	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.1</b>	ug/L	1.0	1		02/13/24 11:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 13		Lab ID: 70286737013	Collected: 02/06/24 06:48	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		02/13/24 11:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 14	Lab ID: 70286737014	Collected: 02/06/24 06:49	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>3.2</b>	ug/L	1.0	1		02/13/24 11:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 16		Lab ID: 70286737015		Collected: 02/06/24 06:32	Received: 02/08/24 13:30	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		02/13/24 11:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 17		Lab ID: 70286737016	Collected: 02/06/24 06:30	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 11:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 18		Lab ID: 70286737017	Collected: 02/06/24 06:31	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 11:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 19		Lab ID: 70286737018	Collected: 02/06/24 06:21	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>18.3</b>	ug/L	1.0	1		02/13/24 11:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 20		Lab ID: 70286737019	Collected: 02/06/24 06:22	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>13.2</b>	ug/L	1.0	1		02/13/24 11:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 21		Lab ID: 70286737020	Collected: 02/06/24 06:25	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 11:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 22	Lab ID: 70286737021	Collected: 02/06/24 06:29	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/13/24 11:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 23		Lab ID: 70286737022		Collected: 02/06/24 06:19	Received: 02/08/24 13:30	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		02/13/24 11:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 24</b>								
<b>Lab ID: 70286737023</b>								
Collected: 02/06/24 06:20								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>6.0</b>	ug/L	1.0	1		02/13/24 11:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 25	Lab ID: 70286737024	Collected: 02/06/24 06:20	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>3.8</b>	ug/L	1.0	1		02/13/24 11:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 26		Lab ID: 70286737025	Collected: 02/06/24 06:16	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.8</b>	ug/L	1.0	1		02/13/24 11:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 27	Lab ID: 70286737026	Collected: 02/06/24 06:13	Received: 02/08/24 13:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>5.4</b>	ug/L	1.0	1		02/13/24 11:58	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 28		Lab ID: 70286737027	Collected: 02/06/24 06:11	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 12:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 29		Lab ID: 70286737028	Collected: 02/06/24 06:14	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 12:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 30</b>								
<b>Lab ID: 70286737029</b>								
Collected: 02/06/24 06:09								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.6	ug/L	1.0	1		02/13/24 12:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 31		Lab ID: 70286737030	Collected: 02/06/24 06:07	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		02/13/24 12:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 32		Lab ID: 70286737031	Collected: 02/06/24 06:06	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>19.8</b>	ug/L	1.0	1		02/13/24 12:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 33		Lab ID: 70286737032	Collected: 02/06/24 06:17	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 12:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 34		Lab ID: 70286737033	Collected: 02/06/24 06:18	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 12:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 35</b>								
<b>Lab ID: 70286737034</b>								
Collected: 02/06/24 06:57								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		02/13/24 12:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 36	Lab ID: 70286737035	Collected: 02/06/24 06:57	Received: 02/08/24 13:30	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>8.1</b>	ug/L	1.0	1		02/13/24 12:16	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 37		Lab ID: 70286737036	Collected: 02/06/24 06:59	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.7</b>	ug/L	1.0	1		02/13/24 12:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 38		Lab ID: 70286737037	Collected: 02/06/24 06:59	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		02/13/24 12:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 39		Lab ID: 70286737038	Collected: 02/06/24 07:00	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		02/13/24 12:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 40</b>								
<b>Lab ID: 70286737039</b>								
Collected: 02/06/24 07:01								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.4	ug/L	1.0	1		02/13/24 12:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 41	Lab ID: 70286737040	Collected: 02/06/24 07:02	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>5.5</b>	ug/L	1.0	1		02/13/24 12:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 42		Lab ID: 70286737041	Collected: 02/06/24 07:02	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.9</b>	ug/L	1.0	1		02/13/24 12:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 43</b>								
<b>Lab ID: 70286737042</b>								
Collected: 02/06/24 07:05								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>10.4</b>	ug/L	1.0	1		02/13/24 12:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 44		Lab ID: 70286737043	Collected: 02/06/24 07:06	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>15.7</b>	ug/L	1.0	1		02/13/24 12:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 45		Lab ID: 70286737044	Collected: 02/06/24 07:07	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.1</b>	ug/L	1.0	1		02/13/24 12:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 46		Lab ID: 70286737045		Collected: 02/06/24 07:07	Received: 02/08/24 13:30	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		02/13/24 12:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 47		Lab ID: 70286737046	Collected: 02/06/24 07:08	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.0</b>	ug/L	1.0	1		02/13/24 12:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 48	Lab ID: 70286737047	Collected: 02/06/24 07:09	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.1</b>	ug/L	1.0	1		02/13/24 12:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 49	Lab ID: 70286737048	Collected: 02/06/24 06:55	Received: 02/08/24 13:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.2</b>	ug/L	1.0	1		02/13/24 12:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: JE 50</b>								
<b>Lab ID: 70286737049</b>								
Collected: 02/06/24 06:55								
Received: 02/08/24 13:30								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.9</b>	ug/L	1.0	1		02/13/24 12:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 51		Lab ID: 70286737050	Collected: 02/06/24 07:04	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>27.4</b>	ug/L	1.0	1		02/13/24 12:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 52		Lab ID: 70286737051	Collected: 02/06/24 07:04	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.6</b>	ug/L	1.0	1		02/13/24 12:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 53		Lab ID: 70286737052	Collected: 02/06/24 06:24	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>14.6</b>	ug/L	1.0	1		02/13/24 13:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 54		Lab ID: 70286737053	Collected: 02/06/24 06:27	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.5</b>	ug/L	1.0	1		02/13/24 13:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 55		Lab ID: 70286737054	Collected: 02/06/24 06:38	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 13:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 56		Lab ID: 70286737055	Collected: 02/06/24 06:51	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		02/13/24 13:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Sample: JE 57		Lab ID: 70286737056	Collected: 02/06/24 06:52	Received: 02/08/24 13:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.2</b>	ug/L	1.0	1		02/13/24 13:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

QC Batch:	337199	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70286737001, 70286737002, 70286737003, 70286737004, 70286737005, 70286737006, 70286737007, 70286737008, 70286737009, 70286737010, 70286737011, 70286737012, 70286737013, 70286737014, 70286737015, 70286737016, 70286737017, 70286737018, 70286737019, 70286737020		

METHOD BLANK:	1733830	Matrix:	Water
Associated Lab Samples:	70286737001, 70286737002, 70286737003, 70286737004, 70286737005, 70286737006, 70286737007, 70286737008, 70286737009, 70286737010, 70286737011, 70286737012, 70286737013, 70286737014, 70286737015, 70286737016, 70286737017, 70286737018, 70286737019, 70286737020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/13/24 10:49	

LABORATORY CONTROL SAMPLE:	1733831					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE:	1733834						
Parameter	Units	70286737001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	43.6	87	70-130	

MATRIX SPIKE SAMPLE:	1733836						
Parameter	Units	70286737002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	45.7	91	70-130	

SAMPLE DUPLICATE:	1733833				
Parameter	Units	70286737001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	1733835				
Parameter	Units	70286737002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

QC Batch:	337200	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70286737021, 70286737022, 70286737023, 70286737024, 70286737025, 70286737026, 70286737027, 70286737028, 70286737029, 70286737030, 70286737031, 70286737032, 70286737033, 70286737034, 70286737035, 70286737036, 70286737037, 70286737038, 70286737039, 70286737040		

METHOD BLANK:	1733837	Matrix:	Water
Associated Lab Samples:	70286737021, 70286737022, 70286737023, 70286737024, 70286737025, 70286737026, 70286737027, 70286737028, 70286737029, 70286737030, 70286737031, 70286737032, 70286737033, 70286737034, 70286737035, 70286737036, 70286737037, 70286737038, 70286737039, 70286737040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/13/24 11:38	

LABORATORY CONTROL SAMPLE:	1733838					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.9	106	85-115	

MATRIX SPIKE SAMPLE:	1733840						
Parameter	Units	70286737021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	43.9	87	70-130	

MATRIX SPIKE SAMPLE:	1733842						
Parameter	Units	70286737022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.7	50	52.6	98	70-130	

SAMPLE DUPLICATE:	1733839				
Parameter	Units	70286737021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	1733841				
Parameter	Units	70286737022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.7	3.8	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

QC Batch:	337201	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70286737041, 70286737042, 70286737043, 70286737044, 70286737045, 70286737046, 70286737047, 70286737048, 70286737049, 70286737050, 70286737051, 70286737052, 70286737053, 70286737054, 70286737055, 70286737056		

METHOD BLANK:	1733843	Matrix:	Water
Associated Lab Samples:	70286737041, 70286737042, 70286737043, 70286737044, 70286737045, 70286737046, 70286737047, 70286737048, 70286737049, 70286737050, 70286737051, 70286737052, 70286737053, 70286737054, 70286737055, 70286737056		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/13/24 12:28	

LABORATORY CONTROL SAMPLE:	1733844					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.0	106	85-115	

MATRIX SPIKE SAMPLE:	1733846						
Parameter	Units	70286737041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.9	50	52.5	97	70-130	

MATRIX SPIKE SAMPLE:	1733848						
Parameter	Units	70286737042 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	10.4	50	62.2	104	70-130	

SAMPLE DUPLICATE:	1733845					
Parameter	Units	70286737041 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.9	3.9	0		

SAMPLE DUPLICATE:	1733847					
Parameter	Units	70286737042 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	10.4	10.3	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70286737001	JE 01	EPA 200.8	337199		
70286737002	JE 02	EPA 200.8	337199		
70286737003	JE 03	EPA 200.8	337199		
70286737004	JE 04	EPA 200.8	337199		
70286737005	JE 05	EPA 200.8	337199		
70286737006	JE 06	EPA 200.8	337199		
70286737007	JE 07	EPA 200.8	337199		
70286737008	JE 08	EPA 200.8	337199		
70286737009	JE 09	EPA 200.8	337199		
70286737010	JE 10	EPA 200.8	337199		
70286737011	JE 11	EPA 200.8	337199		
70286737012	JE 12	EPA 200.8	337199		
70286737013	JE 13	EPA 200.8	337199		
70286737014	JE 14	EPA 200.8	337199		
70286737015	JE 16	EPA 200.8	337199		
70286737016	JE 17	EPA 200.8	337199		
70286737017	JE 18	EPA 200.8	337199		
70286737018	JE 19	EPA 200.8	337199		
70286737019	JE 20	EPA 200.8	337199		
70286737020	JE 21	EPA 200.8	337199		
70286737021	JE 22	EPA 200.8	337200		
70286737022	JE 23	EPA 200.8	337200		
70286737023	JE 24	EPA 200.8	337200		
70286737024	JE 25	EPA 200.8	337200		
70286737025	JE 26	EPA 200.8	337200		
70286737026	JE 27	EPA 200.8	337200		
70286737027	JE 28	EPA 200.8	337200		
70286737028	JE 29	EPA 200.8	337200		
70286737029	JE 30	EPA 200.8	337200		
70286737030	JE 31	EPA 200.8	337200		
70286737031	JE 32	EPA 200.8	337200		
70286737032	JE 33	EPA 200.8	337200		
70286737033	JE 34	EPA 200.8	337200		
70286737034	JE 35	EPA 200.8	337200		
70286737035	JE 36	EPA 200.8	337200		
70286737036	JE 37	EPA 200.8	337200		
70286737037	JE 38	EPA 200.8	337200		
70286737038	JE 39	EPA 200.8	337200		
70286737039	JE 40	EPA 200.8	337200		
70286737040	JE 41	EPA 200.8	337200		
70286737041	JE 42	EPA 200.8	337201		
70286737042	JE 43	EPA 200.8	337201		
70286737043	JE 44	EPA 200.8	337201		
70286737044	JE 45	EPA 200.8	337201		
70286737045	JE 46	EPA 200.8	337201		
70286737046	JE 47	EPA 200.8	337201		
70286737047	JE 48	EPA 200.8	337201		
70286737048	JE 49	EPA 200.8	337201		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: JEFFERSON ELEMENTARY 2/6

Pace Project No.: 70286737

---

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70286737049	JE 50	EPA 200.8	337201		
70286737050	JE 51	EPA 200.8	337201		
70286737051	JE 52	EPA 200.8	337201		
70286737052	JE 53	EPA 200.8	337201		
70286737053	JE 54	EPA 200.8	337201		
70286737054	JE 55	EPA 200.8	337201		
70286737055	JE 56	EPA 200.8	337201		
70286737056	JE 57	EPA 200.8	337201		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



WO#: 70286737



Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**CHAIN-OF-CUSTODY Analytical Request Document**  
 Contact/Report To: Tiffany Service  
 Phone #: 315-927-4110  
 E-Mail: [taseservice@uticaschools.org](mailto:taseservice@uticaschools.org)  
 Cc E-Mail:

Company Name: OHM BOCES-Utica City School District  
 Street Address: 929 York St Utica, NY 13502  
 Customer Project #: Utica CSD  
 Project Name: Jefferson Elementary  
 Site Collection Info/Facility ID (as applicable): Jefferson Elementary  
 Invoice To: Tiffany Service  
 Invoice E-Mail: [taseservice@uticaschools.org](mailto:taseservice@uticaschools.org)  
 Purchase Order # (if applicable):  
 Quote #: Pace Project Manager: Jack Germano  
 Country / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW  
 Rush (Pre-approval required):  
 ( ) 2 Day ( ) 3 day ( ) 5 day ( ) Other:  
 Date Results Requested: Standard 10 business day  
 Field Filtered (if applicable): ( ) Yes ( ) No  
 Analysis:

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk


Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Res. CLZ	Composite End		Number & Type of Containers	Preservation non-conformance identified for sample
			Date	Time		Date	Time		
JE 01	DW	G	2/6/24	6:32				1	X
JE 02			2/6/24	6:34					
JE 03			2/6/24	6:34					
JE 04			2/6/24	6:36					
JE 05			2/6/24	6:39					
JE 06			2/6/24	6:41					
JE 07			2/6/24	6:44					
JE 08			2/6/24	6:44					
JE 09			2/6/24	6:44					
JE 10			2/6/24	6:46					

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)  
 Signature: Richard Paszkiewicz  
 Received by/Company: Signature: *[Signature]*  
 Date/Time: 2/8/24 13:30  
 Received by/Company: Signature: *[Signature]*  
 Date/Time: 2/6/24 13:30  
 Received by/Company: Signature: *[Signature]*  
 Date/Time: 2/6/24 13:30  
 Received by/Company: Signature: *[Signature]*  
 Date/Time: 2/6/24 13:30  
 Received by/Company: Signature: *[Signature]*  
 Date/Time: 2/6/24 13:30

Tracking Number: 2/8/24 1330  
 Delivered by: ( ) In-Person ( ) Courier  
 ( ) FedEx ( ) UPS ( ) Other  
 Page: 1 of 16

Submit this sample with this chain of custody constitutes acknowledgment and acceptance of the Pace\* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-term-and-conditions/>  
 2/9 8:00  
 MR PACE U

**LAB USE ONLY - Affix Workorder/Login Label Here**



Scan QR Code for instructions

**CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace\* Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: OHM BOCES-Utica City School District  
 Street Address: 929 York St Utica, NY 13502

Customer Project #: Utica CSD  
 Project Name: Jefferson Elementary

Contact/Report To: Tiffany Service  
 Phone #: 315-927-4110  
 E-Mail: tservice@uticaschools.org  
 Cc E-Mail:

Invoice To: Tiffany Service  
 Invoice E-Mail: tservice@uticaschools.org

Purchase Order # (if applicable):  
 Quote #:  
 Pace Project Manager: Jack Germano

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW  
 Rush (Pre-approval required):  
 DW PWSID # or WW Permit # as applicable:  
 ( ) 2 Day ( ) 3 day ( ) 5 day ( ) Other:  
 Date Results Requested: Standard 10 business day  
 Field Filtered (if applicable): ( ) Yes ( ) No  
 Analysis:  
 \* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Biossassy (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers		Sample Comment
			Date	Time	Date	Time		Plastic	Glass	
JE 11	DW	G	2/16/24	646				1		X 200.8 Drinking Water (Pb only)
JE 12			2/16/24	646						
JE 13			2/16/24	646						
JE 14			2/16/24	649						
JE 16			2/16/24	632						
JE 17			2/16/24	630						
JE 18			2/16/24	631						
JE 19			2/16/24	621						
JE 20			2/16/24	622						
JE 21			2/16/24	625						

Lab Use Only  
 Proj. Mgr: Jack Germano  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID:

\*\*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Obs. Temp. (°C) Corrected Temp. (°C)  
 Tracking Number:  
 Date/Time: 2/8/24 1330  
 Date/Time:  
 Delivered by: ( ) In-Person ( ) Courier  
 ( ) FedEx ( ) UPS ( ) Other  
 Page: 12 of 16

Collected By: Richard Paszkiewicz  
 Printed Name:  
 Signature: [Signature]  
 Received by/Company: [Signature] PALE  
 Received by/Company: [Signature]  
 Received by/Company: [Signature]  
 Received by/Company: [Signature] Pace -  
 MRC PALE U  
 2/9 8:00  
 2/9 8:00



LAB USE ONLY - Affix Workorder/Login Label Here

Scan QR Code for instructions

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**CHAIN-OF-CUSTODY Analytical Request Document**

**Pace** Location Requested (City/State): Pace Analytical Long Island NY 575 Broad Hollow Rd, Melville, NY 11747

Company Name: OHM BOCES-Utica City School District  
Street Address: 929 York St Utica, NY 13502

Contact/Report To: **Tiffany Service**  
Phone #: 315-927-4110  
E-Mail: [taservice@uticaschools.org](mailto:taservice@uticaschools.org)  
Cc E-Mail:

Invoice To: **Tiffany Service**  
Invoice E-Mail: [taservice@uticaschools.org](mailto:taservice@uticaschools.org)

Purchase Order # (if applicable):  
Quote #: **Pace Project Manager: Jack Germano**

Country / State origin of sample(s): **New York**

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

**Rush (Pre-approval required):**  
 2 Day  3 day  5 day  Other \_\_\_\_\_  
 Date Results Requested: **Standard 10 business day**

Field Filtered (if applicable):  Yes  No  
Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Time Zone Collected: <input type="checkbox"/> AK <input type="checkbox"/> PT <input type="checkbox"/> MT <input type="checkbox"/> CT <input checked="" type="checkbox"/> ET	Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Res. CL2	Composite End		Number & Type of Containers Plastic Glass	200.0 Drinking Water (Pb only)	Preservation non-conformance identified for sample
				Date	Time		Date	Time			
	JE 22	DW	G	2/6/24	6:29				1	X	
	JE 23			2/6/24	6:19						
	JE 24			2/6/24	6:20						
	JE 25			2/6/24	6:20						
	JE 26			2/6/24	6:16						
	JE 27			2/6/24	6:14						
	JE 28			2/6/24	6:11						
	JE 29			2/6/24	6:14						
	JE 30			2/6/24	6:09						
	JE 31			2/6/24	6:07						

Additional Instructions from Pace:

Collected By: *Richard Reszkiewicz*  
Printed Name: \_\_\_\_\_  
Signature: *Richard Reszkiewicz*

# Coolers: \_\_\_\_\_ Thermometer ID: \_\_\_\_\_ Obs. Temp. (°C) \_\_\_\_\_ Corrected Temp. (°C) \_\_\_\_\_

Trading Number: \_\_\_\_\_  
Date/Time: *2/8/24 1330*

Delivered by:  In-Person  Courier  
 FedEx  UPS  Other

Date/Time: *2/8/24 08:50*  
Signature: *James Pace*

Date/Time: *2/9 4:10*  
Signature: *James Pace*

Page: *23* of *26*

Submit a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace\* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

*MR PACE U 2/9 8:00*





LAB USE ONLY - Affix Workorder/Login Label Here

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Scan QR Code for instructions

Project Name: **Utica USD**  
 Jefferson Elementary

Company Name: **OHM BOCES-Utica City School District**  
 Street Address: **925 York St Utica, NY 13502**

Contact/Report To: **Tiffany Service**  
 Phone #: **315-927-4110**  
 E-Mail: **taservice@uticaschools.org**  
 Cc E-Mail:

Invoice To: **Tiffany Service**  
 Invoice E-Mail: **taservice@uticaschools.org**  
 Purchase Order # (if applicable):  
 Quote #:

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET  
 Data Deliverables:  
 [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other: \_\_\_\_\_

Project Manager: **Jack Germano**  
 County/State origin of sample(s): **New York**  
 Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**  
 Rush (pre-approval required): **DW PWSID # or WW Permit # as applicable:**  
 [ ] 1-2 Day [ ] 3 day [ ] 5 day [ ] Other: \_\_\_\_\_  
 Date Results Requested: **Standard 10 business day**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Res. CL2	Composite End		Number & Type of Containers	Sample Comment
			Date	Time		Date	Time		
JE 42	DW	G	2/16/24	702				1	X
JE 43			2/16/24	705					
JE 44			2/16/24	706					
JE 45			2/16/24	707					
JE 46			2/16/24	707					
JE 47			2/16/24	708					
JE 48			2/16/24	709					
JE 49			2/16/24	655					
JE 50			2/16/24	655					
JE 51			2/16/24	704					

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Additional Instructions from Pace\*:  
 Collected By: **Richard Resnikowicz**  
 Printed Name:  
 Signature: *[Signature]*  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**

Customer Remarks / Special Conditions / Possible Hazards:  
 Lead  
 200.8 Drinking Water (Pb only) X

Preservation non-conformance identified for sample:

Proj. Mgr: **Jack Germano**  
 AcciNum / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID:

Lab Use Only

Specify Container Size \*\*  
 \*\* Container Size: (1) 1L, (2) 500ml, (3) 250ml, (4) 125ml, (5) 100ml, (6) 40ml vial, (7) Encore, (8) TerraCore, (9) Other  
 Identify Container Preservative Type\*\*\*  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested

Tracking Number:  
 Date/Time: **2/18/24 1330**  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other  
 Page: **15 of 16**

Additional Information:  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**  
 Received by/Company: **PACE**  
 Signature: *[Signature]*  
 Date/Time: **2/18/24 1330**







**WO#: 70286737**  
**PM: JMG** **Due Date: 02/19/24**  
**CLIENT: UticaCityCSD**

Client Name: UTICA Project # \_\_\_\_\_  
 Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pac  Other \_\_\_\_\_  
 Tracking #: \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other \_\_\_\_\_ Type of Ice: Wet Blue  None  
 Thermometer Used: TH211 Correction Factor: +0.4  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 19.3 Cooler Temperature Corrected (°C): 19.7 Date/Time 5035A kits placed in freezer \_\_\_\_\_  
 Temp should be above freezing to 6.0°C

USDA Regulated Soil ( N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: MPL 2/19

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	

Date and Initials of person checking preservation: MPL 2/19

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>2H 213623V</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15.
SM 4500 CN samples checked for sulf <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Positive for Sulfide? Y N
Lead Acetate Strips Lot #	16.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: [Signature]

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/ Resolution: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\* PM (Project Manager) review is documented electronically in LIMS.