

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Location	Action
PHS-01	2/8/2024 05:02	2/14/2024 13:19	70286967001	Lead	<1.0	5	ug/L		
PHS-02	2/8/2024 05:04	2/14/2024 13:20	70286967002	Lead	<1.0	5	ug/L		
PHS-03	2/8/2024 05:06	2/14/2024 13:22	70286967003	Lead	<1.0	5	ug/L		
PHS-04	2/8/2024 05:05	2/14/2024 13:26	70286967004	Lead	<1.0	5	ug/L		
PHS-05	2/8/2024 05:11	2/14/2024 13:28	70286967005	Lead	2.1	5	ug/L		
PHS-06	2/8/2024 05:11	2/14/2024 13:29	70286967006	Lead	<1.0	5	ug/L		
PHS-07	2/8/2024 05:12	2/14/2024 13:31	70286967007	Lead	1.1	5	ug/L		
PHS-08	2/8/2024 05:14	2/14/2024 13:33	70286967008	Lead	<1.0	5	ug/L		
PHS-09	2/8/2024 05:15	2/14/2024 13:34	70286967009	Lead	1.0	5	ug/L		
PHS-10	2/8/2024 05:17	2/14/2024 13:36	70286967010	Lead	2.1	5	ug/L		
PHS-11	2/8/2024 05:17	2/14/2024 13:40	70286967011	Lead	3.9	5	ug/L		
PHS-12	2/8/2024 05:19	2/14/2024 13:48	70286967012	Lead	<1.0	5	ug/L		
PHS-13	2/8/2024 05:21	2/14/2024 13:52	70286967013	Lead	<1.0	5	ug/L		
PHS-14	2/8/2024 05:22	2/14/2024 13:54	70286967014	Lead	<1.0	5	ug/L		
PHS-15	2/8/2024 05:22	2/14/2024 13:55	70286967015	Lead	<1.0	5	ug/L		
PHS-16	2/8/2024 05:25	2/14/2024 13:57	70286967016	Lead	1.5	5	ug/L		
PHS-17	2/8/2024 05:26	2/14/2024 13:58	70286967017	Lead	71.7	5	ug/L	sink room M104	sign posted
PHS-18	2/8/2024 05:28	2/14/2024 14:03	70286967018	Lead	<1.0	5	ug/L		
PHS-19	2/8/2024 05:30	2/14/2024 14:04	70286967019	Lead	<1.0	5	ug/L		
PHS-20	2/8/2024 05:32	2/14/2024 14:06	70286967020	Lead	<1.0	5	ug/L		
PHS-21	2/8/2024 05:30	2/14/2024 14:08	70286967021	Lead	<1.0	5	ug/L		
PHS-22	2/8/2024 05:37	2/14/2024 14:09	70286967022	Lead	<1.0	5	ug/L		
PHS-23	2/8/2024 05:39	2/14/2024 14:11	70286967023	Lead	2.1	5	ug/L		
PHS-24	2/8/2024 05:40	2/14/2024 14:12	70286967024	Lead	<1.0	5	ug/L		
PHS-25	2/8/2024 05:42	2/14/2024 14:14	70286967025	Lead	<1.0	5	ug/L		
PHS-26	2/8/2024 05:44	2/14/2024 14:16	70286967026	Lead	<1.0	5	ug/L		
PHS-27	2/8/2024 05:45	2/14/2024 14:17	70286967027	Lead	1.4	5	ug/L		
PHS-28	2/8/2024 05:47	2/14/2024 14:22	70286967028	Lead	<1.0	5	ug/L		
PHS-29	2/8/2024 05:48	2/14/2024 14:23	70286967029	Lead	<1.0	5	ug/L		
PHS-30	2/8/2024 05:50	2/14/2024 14:25	70286967030	Lead	<1.0	5	ug/L		
PHS-31	2/8/2024 05:51	2/14/2024 14:29	70286967031	Lead	<1.0	5	ug/L		
PHS-32	2/8/2024 05:53	2/14/2024 14:34	70286967032	Lead	2.6	5	ug/L		
PHS-33	2/8/2024 05:54	2/14/2024 14:41	70286967033	Lead	<1.0	5	ug/L		
PHS-34	2/8/2024 05:56	2/14/2024 14:43	70286967034	Lead	<1.0	5	ug/L		
PHS-35	2/8/2024 05:57	2/14/2024 14:44	70286967035	Lead	<1.0	5	ug/L		
PHS-36	2/9/2024 05:02	2/14/2024 14:46	70286967036	Lead	<1.0	5	ug/L		
PHS-37	2/9/2024 05:06	2/14/2024 14:48	70286967037	Lead	<1.0	5	ug/L		
PHS-38	2/9/2024 05:09	2/14/2024 14:49	70286967038	Lead	<1.0	5	ug/L		
PHS-39	2/9/2024 05:09	2/14/2024 14:51	70286967039	Lead	<1.0	5	ug/L		
PHS-40	2/9/2024 05:10	2/14/2024 14:52	70286967040	Lead	<1.0	5	ug/L		
PHS-41	2/9/2024 05:12	2/14/2024 14:54	70286967041	Lead	<1.0	5	ug/L		
PHS-42	2/9/2024 05:14	2/14/2024 14:58	70286967042	Lead	<1.0	5	ug/L		
PHS-43	2/9/2024 05:17	2/14/2024 15:00	70286967043	Lead	<1.0	5	ug/L		
PHS-44	2/9/2024 05:17	2/14/2024 15:01	70286967044	Lead	<1.0	5	ug/L		
PHS-45	2/9/2024 05:19	2/14/2024 15:03	70286967045	Lead	<1.0	5	ug/L		
PHS-46	2/9/2024 05:21	2/14/2024 15:05	70286967046	Lead	<1.0	5	ug/L		
PHS-47	2/9/2024 05:22	2/14/2024 15:06	70286967047	Lead	<1.0	5	ug/L		
PHS-48	2/9/2024 05:23	2/14/2024 15:08	70286967048	Lead	<1.0	5	ug/L		
PHS-49	2/9/2024 05:24	2/14/2024 15:09	70286967049	Lead	<1.0	5	ug/L		
PHS-50	2/9/2024 05:25	2/14/2024 15:11	70286967050	Lead	<1.0	5	ug/L		
PHS-51	2/9/2024 05:21	2/14/2024 15:18	70286967051	Lead	<1.0	5	ug/L		
PHS-52	2/9/2024 05:30	2/14/2024 15:23	70286967052	Lead	<1.0	5	ug/L		
PHS-53	2/9/2024 05:32	2/14/2024 15:27	70286967053	Lead	<1.0	5	ug/L		
PHS-54	2/9/2024 05:33	2/14/2024 15:29	70286967054	Lead	<1.0	5	ug/L		
PHS-55	2/9/2024 05:34	2/14/2024 15:30	70286967055	Lead	<1.0	5	ug/L		
PHS-56	2/9/2024 05:35	2/14/2024 15:35	70286967056	Lead	<1.0	5	ug/L		
PHS-57	2/9/2024 05:37	2/14/2024 15:36	70286967057	Lead	2.5	5	ug/L		
PHS-58	2/9/2024 05:40	2/14/2024 15:38	70286967058	Lead	<1.0	5	ug/L		
PHS-59	2/9/2024 05:41	2/14/2024 15:40	70286967059	Lead	<1.0	5	ug/L		
PHS-60	2/9/2024 05:42	2/14/2024 15:41	70286967060	Lead	<1.0	5	ug/L		
PHS-61	2/9/2024 05:43	2/14/2024 15:43	70286967061	Lead	<1.0	5	ug/L		
PHS-62	2/9/2024 05:45	2/14/2024 15:44	70286967062	Lead	<1.0	5	ug/L		
PHS-63	2/9/2024 05:51	2/14/2024 15:46	70286967063	Lead	3.2	5	ug/L		

PHS-64	2/9/2024 05:51	2/14/2024 15:47	70286967064	Lead	<1.0	5	ug/L		
PHS-65	2/9/2024 05:51	2/14/2024 15:49	70286967065	Lead	<1.0	5	ug/L		
PHS-66	2/9/2024 05:53	2/14/2024 15:54	70286967066	Lead	<1.0	5	ug/L		
PHS-67	2/9/2024 05:55	2/14/2024 15:55	70286967067	Lead	<1.0	5	ug/L		
PHS-68	2/9/2024 05:56	2/14/2024 15:57	70286967068	Lead	<1.0	5	ug/L		
PHS-69	2/9/2024 05:56	2/14/2024 15:58	70286967069	Lead	1.8	5	ug/L		
PHS-70	2/9/2024 05:58	2/14/2024 16:00	70286967070	Lead	1.8	5	ug/L		
PHS-71	2/9/2024 05:58	2/14/2024 16:04	70286967071	Lead	<1.0	5	ug/L		
PHS-72	2/9/2024 05:59	2/14/2024 16:12	70286967072	Lead	<1.0	5	ug/L		
PHS-73	2/9/2024 06:02	2/14/2024 16:16	70286967073	Lead	<1.0	5	ug/L		
PHS-74	2/9/2024 06:02	2/14/2024 16:18	70286967074	Lead	<1.0	5	ug/L		
PHS-75	2/9/2024 06:04	2/14/2024 16:19	70286967075	Lead	<1.0	5	ug/L		
PHS-76	2/9/2024 06:05	2/14/2024 16:21	70286967076	Lead	<1.0	5	ug/L		
PHS-77	2/9/2024 06:05	2/14/2024 16:23	70286967077	Lead	<1.0	5	ug/L		
PHS-78	2/9/2024 06:05	2/14/2024 16:24	70286967078	Lead	<1.0	5	ug/L		
PHS-79	2/9/2024 06:08	2/14/2024 16:26	70286967079	Lead	<1.0	5	ug/L		
PHS-80	2/9/2024 06:12	2/14/2024 16:30	70286967080	Lead	<1.0	5	ug/L		
PHS-81	2/9/2024 06:16	2/14/2024 16:32	70286967081	Lead	<1.0	5	ug/L		
PHS-82	2/9/2024 06:18	2/14/2024 16:33	70286967082	Lead	2.2	5	ug/L		
PHS-83	2/9/2024 06:24	2/14/2024 16:35	70286967083	Lead	7.7	5	ug/L	Rm M197 sink	sign posted
PHS-84	2/9/2024 06:25	2/14/2024 16:37	70286967084	Lead	122	5	ug/L	Rm 199 sink	sign posted

NYSDOH Action Level for Lead In Schools of 5 ppb